



NO.	PDM code	Name	Specification and Model	Estimated replacement interval	Notes
1	2011051	Stack	Specification: Epstack4/Epstack5	N/A	requires RKP authorized personal
2	5030221	Pump	Model: 4-20mA; Specification: BT-UPower104-pump-0002	~ 5 - 8 years	requires RKP authorized personal
3	5040183	DC Fan	Model: 48V; Specification: THB1548EG-00P6	~ 3 - 5 years	
4	5050188	Temperature sensor	Model: 1.5m; Specification: WZP-035F4-1.5A-2S/Pt100-P-4W-1.5M	>5 Years	
5	5050171	Leakage sensor probe	Specification: ST-leak carbon brush-02	>5 Years	To be regularly monitored
6	5040106	Air filter	Model: G2 filter cotton; Specification: SVF105-G2;	depends on pollution level	
7	5072377	Drive	Version Number: UP_Drive_V1.1	N/A	
8	5072805	Signal module	Version Number: UP_SIGNAL_V1.3	N/A	requires RKP authorized personal
9	5072379	Core controller	Version Number: UP_MainControl_V1.1	N/A	requires RKP authorized personal



<b>Document Version</b>	<b>Release Date</b>	<b>Revision History</b>
V1.0	2025-04-16	<b>Official Launch (V1.0)</b>