

NO.	PDM code	Name	Specification and Model	Estimated replacement interval	Notes
1	02011101	Stack	Specification: Tstack10-Bi-52J	N/A	requires RKP authorized personal
2	05030219	Pump	Model: AC380V/50Hz; Specification: ST-Pump-09	~ 5-8 years	requires RKP authorized personal
3	05040270	DC Fan	Specification: SC225F5-075-001-104	~ 3-5 years	
4	05050135	Temperature sensor	Specification: ST-PT100 temperature sensor-01	>5 Years	
5	05050170	Leakage sensor probe	Specification: ST-leak carbon brush-01	>5 Years	
6	05040267/ 05040268	Air Filters	Specification: 400X1000,DC24V, 3W/395X395,DC24V, 3W	depends on pollution level	
7	05072377	Drive	Version Number: UP_Drive_V1.1	N/A	requires RKP authorized personal
8	05072805	Signal module	Version Number: UP_SIGNAL_V1.3	N/A	requires RKP authorized personal
9	05072379	Core controller	Version Number: UP_MainControl_V1.1	N/A	requires RKP authorized personal
10	05050620	Electric Heater (plastic casing)	Model: RCS 030(1500W)	N/A	
11	05030234	Gas diaphragm pump	Specification: 24VDC	N/A	
12	05040271	Industrial air conditioner	Specification: BT-SPower240o-Aircondition-0001	N/A	



Document Version	Release Date	Revision History
V1.0	2025-04-16	Official Launch (V1.0)